

## Aurora Universal Revenue Grade Current Transducer Sizing Chart

### For 240 VAC, Single Phase Renewable Energy Systems:

System Size (kW)	Meter System	CT Type	CT Inner Diameter
8 - 14	Aurora Universal Revenue Grade	50:5 Amp	3/4"
14 - 28	Aurora Universal Revenue Grade	100:5 Amp	1"
28 - 57	Aurora Universal Revenue Grade	200:5 Amp	2"
57 - 115	Aurora Universal Revenue Grade	400:5 Amp	3"
115 - 172	Aurora Universal Revenue Grade	600:5 Amp	3"
greater than 172	Aurora Universal Revenue Grade	special order	special order

### For 208 VAC, Three Phase Renewable Energy Systems:

System Size (kW)	Meter System	CT Type	CT Inner Diameter
11 - 21	Aurora Universal Revenue Grade	50:5 Amp	3/4"
21 - 43	Aurora Universal Revenue Grade	100:5 Amp	1"
43 - 86	Aurora Universal Revenue Grade	200:5 Amp	2"
86 - 172	Aurora Universal Revenue Grade	400:5 Amp	3"
172 - 259	Aurora Universal Revenue Grade	600:5 Amp	3"
greater than 259	Aurora Universal Revenue Grade	special order	special order

### For 480 VAC, Three Phase Renewable Energy Systems:

System Size (kW)	Meter System	CT Type	CT Inner Diameter
27 - 49	Aurora Universal Revenue Grade	50:5 Amp	3/4"
49 - 99	Aurora Universal Revenue Grade	100:5 Amp	1"
99 - 199	Aurora Universal Revenue Grade	200:5 Amp	2"
199 - 398	Aurora Universal Revenue Grade	400:5 Amp	3"
398 - 597	Aurora Universal Revenue Grade	600:5 Amp	3"
greater than 597	Aurora Universal Revenue Grade	special order	special order